

## EUROPEAN TECHNICAL ASSESSMENT

ETA-15/0355 of 21.11.2023

**ADAY GRUP ÇELİK YAPI VE İNŞAAT A.Ş.**

**MANUFACTURING:** ADAY GRUP ÇELİK YAPI VE İNŞAAT A.Ş.

**MAIN ADDRESS:** SARAY, BAYRAKTAR CD. NO:13/A 06980 KAHRAMANKAZAN / ANKARA / TURKEY

**FACTORY:** IZVAN REGULATSIA 4, 4147 KALEKOVETS PLOVDIV / BULGARIA

**PRODUCT DESCRIPTION :** SELF-SUPPORTING INSULATED COMPOSITE PANELS FOR USE IN INTERNAL AND EXTERNAL WALLS.

**PRODUCT NAME:** ADY FC-SIPW 140- ADY FC-SIPW 100

**MANUFACTURER PLANT(S):** SARAY, BAYRAKTAR CD. NO:13/A 06980 KAHRAMANKAZAN/ANKARA

**THIS EUROPEAN TECHNICAL ASSESSMENT CONTAINS:** 7 PAGES INCLUDING 1 ANNEX

**PRODUCT FAMILY TO WHICH THE CONSTRUCTION PRODUCT BELONGS:** INSULATED WALL PANEL

**RADE NAME OF THE CONSTRUCTION PRODUCT:** ETA100-5 – ETA7950-8 – ETA15000-9 – ETA87041-6

### RELEVANT STANDARDS/ DIRECTIVES/ REGULATIONS

EN 4048 Determination of Specific Heat of Thermal Insulating Materials

EN 13500 Thermal insulation products for buildings - External thermal insulation composite systems (ETICS) based on mineral wool – Specification

EN 13172 Thermal insulation products - Evaluation of conformity

### CERTIFICATION GROUND

**TECHNICAL FILE NO:** ADA-TNQ-2023-ETA-002

The European Technical Assessment is issued by the Tnq Certification Body in its official language. Translations of this Technical Assessment in other languages shall fully correspond to the original issued document and shall be identified as such.

Communication of this TNQ Certification Assessment, including transmission by electronic means, shall be in full.

However, partial reproduction may only be made with the written consent of the issuing


Technical Assessment Body. Any partial reproduction shall be identified as such.

This Technical Assessment may be withdrawn by the issuing Technical Assessment Body, in particular pursuant to information by the Commission in accordance with Article 25(3) of Regulation (EU) No 305/2011.

**EUROPEAN TECHNICAL APPROVAL**  
**ETA-15/0355**



TNQ Academy Training Certification  
Testing and Conformity Assessment Inc.  
Certificate validity information  
certificate@tnqcert.com you can check at  
709 N. King Street  
Suite 260 Wilmington  
DE 19801  
Country : USA  
E-mail: certificate@tnqcert.com  
turkey@tnqcert.com



**PRODUCT INFORMATION**

PRODUCT TYPE	MOST	SIZE	THICKNESS
ADY FC-SIPW 140	1250MM	2500MM	140MM
ADY FC-SIPW 100	1250MM	2500MM	100MM
ADY FC-SIPW 140	1250MM	2800MM	140MM
ADY FC-SIPW 100	1250MM	2800MM	100MM

**Specific Part****1. Technical description of the product**

The Technical Assessment applies to the thermal insulation product made of loose, free cellulose fibres with the designation: "ATP SW".

The cellulose fibres are produced from waste paper by mechanical crushing. During the manufacturing process the product is provided with a fire protection equipment.

The Technical Assessment has been issued for the products on the basis of agreed data/ information, deposited with Deutsches Institut für Bautechnik, which identifies the product that has been assessed. The Technical Assessment applies only to products corresponding to this agreed data/information.

**2. Pecification of the intended use in accordance with the applicable European Assessment Document**

The thermal insulation material serves for the production of insulation layers, not exposed to compression loads, by means of machine processing at the place of use. The machine processing is carried out in dry conditions or under the addition of water. The reaction to fire of the insulating material depends on the end use conditions. Clause 3.2 shall be observed in this regard. The thermal insulation product can be used for the following intended uses:

- Space-filling insulation in closed cavities of external and interior walls of timber frame constructions and similar structures
- Insulation in closed cavities between rafters and timber beams as well as in cavities of corresponding structures
- Exposed insulation on horizontal or moderately pitched areas ( $\leq 10^\circ$ ), e. g. insulation of topmost storey ceilings which are not subjected to foot traffic, however, are accessible
- Cavity insulation between flooring joist battens and similar substructures

The performances given in Section 3 are only valid if the thermal insulation product is installed according to the manufacture's installation instructions, used in compliance with the specifications and conditions given in Annex A and if they are protected from precipitation, wetting or weathering in built-in state and during transport, storage and installation.

The design value of the thermal conductivity shall be laid down according to relevant national provisions.

**EUROPEAN TECHNICAL APPROVAL**  
**ETA-15/0355**



TNQ Academy Training Certification  
Testing and Conformity Assessment Inc.  
Certificate validity information  
certificate@tnqcert.com you can check at  
709 N. King Street  
Suite 260 Wilmington  
DE 19801  
Country : USA  
E-mail: certificate@tnqcert.com  
turkey@tnqcert.com



The verifications and assessment methods on which this European Technical Assessment is based lead to the assumption of a working life of the thermal insulation products of at least 50 years. The indications given on the working life cannot be interpreted as a guarantee given by the producer, but are to be regarded only as a means for choosing the right products in relation to the expected economically reasonable working life of the works.

### 3. Performance of the product and references to the methods used for its assessment

For sampling, conditioning and testing the provisions of the EAD No 040138-01-1201 "In-situ formed loose fill thermal and/or acoustic insulation products made of vegetable fibres" apply.

#### 1.1 Safety in case of fire (BWR 2)

Essential characteristic	Performance
Reaction to fire test acc. to EN ISO 11925-2:2010 test acc. to 13823:2010+A1:2014	Class B-s2, d0 <sup>1</sup> acc. to EN 13501-1:2007+A1:2009
Reaction to fire test acc. to EN ISO 11925-2:2010	Class E <sup>23</sup> acc. to EN 13501-1:2007+A1:2009

#### 1.2 Hygiene, health and the environment (BWR 3)

Essential characteristic	Performance
Resistance to the growth of mould test acc. to EAD "In-situ formed loose fill thermal and/or acoustic insulation products made of vegetable fibres", Annex B	Evaluation level 0 acc. to EN ISO 846:1997

#### 1.3 Protection against noise (BWR 5)

Essential characteristic	Performance
Sound absorption	No performance assessed

#### 1.4 Energy economy and heat retention (BWR 6)

Essential characteristic	Performance
Thermal conductivity at mean reference temperature of 10 °C test acc. to EN 12667:2001	Declared value for a moisture content of the insulation material at 23 °C and 50 % relative humidity <sup>2</sup> : $\lambda_{D(23,50)} = 0.038 \text{ W/(m} \cdot \text{K)}$
Conversion of humidity acc. to EN ISO 10456:2007+AC:2009 mass-related moisture content at 23 °C/50 % rel. humidity:	$u_{23,50} = 0.08 \text{ kg/kg}$
mass-related moisture content at 23 °C/80 % rel. humidity:	$u_{23,80} = 0.13 \text{ kg/kg}$
mass-related moisture conversion coefficient (dry to 23 °C/50 % rel. humidity):	$f_{u1} = 0.20$
mass-related moisture conversion coefficient (23 °C/50 % rel. humidity to 23 °C/80 % rel. humidity):	$f_{u2} = 0.26$
Essential characteristic	Performance
moisture conversion factor (dry to 23 °C/50 % rel. humidity):	$F_{m1} = 1.02$
moisture conversion factor (23 °C/50 % rel. humidity to 23 °C/80 % rel. humidity):	$F_{m2} = 1.02$
Water vapor diffusion resistance coefficient test acc. to EN 12086:2013, climate condition C	$\mu = 1 \text{ b/s } 2^4$



- 1) Installation density of the insulating material 30 kg/m<sup>3</sup> to 60 kg/m<sup>3</sup>, to be used between or on wood-based boards with a board thickness  $\geq 12 \pm 2$  mm or substrates of classes A1 or A2 – s1, d0 according to EN 13501-1 Density of the boards  $\geq 510$  kg/m<sup>3</sup>, insulation layer thickness  $\geq 100$  mm
- 2) Applies to insulation layer thickness  $\geq 40$  mm
- 3) The declared value is representative for at least 90 % of the production with a confidence level of 90 % and applies to the density ranges according to annex A.
- 4) The most unfavourable value for the construction work shall be applied each 5
- 5) Also relevant with regard to BWR 5.

Water absorption	No performance assessed
Corrosion developing capacity test acc. to EN 15101-1, Annex E	CR – Test passed
Settlement	
Settling under impact excitation in the case of free placing (e. g. on the ceiling or between beams)	$\leq 10$ % at a minimum bulk density of 30 kg/m <sup>3</sup> and a maximum thickness of 330 mm
Settling under vibration in wall cavity and between beams	SC 0 acc. to EN 15101-1:2013 at a minimum bulk density of 45 kg/m <sup>3</sup> and a maximum thickness of 240 mm
Settling under defined climatic conditions	No performance assessed
Critical moisture content	No performance assessed
Airflow resistance <sup>s</sup> Test acc. To EN 29053:1993, Method A	$\geq 5,0$ kPa · s/m <sup>2</sup>
Hygroscopic sorption properties	No performance assessed

#### 4. Assessment and verification of constancy of performance (AVCP) system applied, with reference to its legal base

In accordance with the European Assessment Document EAD No. 040138-01-1201, the applicable European legal act is: 1999/91/EC. The system to be applied is: 3

In addition, with regard to reaction to fire the applicable European legal act is: 2001/596/EC for products covered by the European Assessment Document EAD No. 040138-01-1201.

The system to be applied is: 1

#### 5. Technical details necessary for the implementation of the AVCP system, as provided for in the applicable EAD

Technical details necessary for the implementation of the AVCP system are laid down in the control plan deposited with Deutsches Institut für Bautechnik.

**EUROPEAN TECHNICAL APPROVAL**  
**ETA-15/0355**



TNQ Academy Training Certification  
Testing and Conformity Assessment Inc.  
Certificate validity information  
certificate@tnqcert.com you can check at:  
709 N. King Street  
Suite 260 Wilmington  
DE 19801  
Country : USA  
E-mail: certificate@tnqcert.com  
turkey@tnqcert.com



**CelluBOR SW**

**ANNEX A**

The performances of the thermal insulation products given in Section 3 are valid if the following will be considered concerning installation and use:

-Densities at built-in stage:

Area of application	Density [kg/m <sup>3</sup> ]
Cavity insulaion in walls	45 - 60
Cavity insulaion in pitched roofs, cavity insulaion in floors in case of subsequent blowing into closed cavites	40 - 60
Cavity insulaion in floors, exposed insulaion on horizontal and moderately pitched areas ( $\leq 10^\circ$ )	30 - 60

- The density is determined by calculation as a quotient from the mass of the material brought in and the full volume.
- The thermal insulation layer has a constant installation thickness taking account of the nominal thickness. For that purpose, suitable height marks are be arranged by the executing company in sufficient distances before the processing. The executing company check the installation thickness and the density.
- When calculating the thermal resistance of the construction elements, the nominal thickness of the thermal insulation layer is applied as follows:

Processing of the insulaion material	Nominal thickness
Cavity insulaion in walls	clear span of the filled cavity
Cavity insulaion in pitched roofs, cavity insulaion in floors in case of subsequent blowing into closed cavites	clear span of the filled cavity
Cavity insulaion in floors, exposed insulaion on horizontal, and moderately pitched areas ( $\leq 10^\circ$ )	insulatiin thickness of the insulaion material minus 10 %

- The requirements concerning ventilation openings and the ventilation section above the thermal insulation layer are considered.
- In case of installation on pitched or arched areas slipping of the thermal insulation product is prevented by suitable measures.
- In case of use as space-filling thermal insulation in closed cavities it is made sure by appropriate measures (e. g. control drillings) that the cavity is completely filled with the thermal insulation product.
- The installation instructions given by the manufacturer shall be taken into account. Machine installation of the insulating materials shall be performed by companies trained by the manufacturer. In case of processing under the addition of water it shall be ensured that the main share of water is evaporated before closing the cavity. The tim period necessary for this depends on the climatic conditions of the surroundings. Only building materials allowing an evaporation of moisture may be used as facing.
- The thermal insulation products are only processed by companies stated in a list of the manufacturer which have adequate experience in installing the material. Concerning this matter the manufacturer has trained these companies.

**EUROPEAN TECHNICAL APPROVAL**  
**ETA-15/0355**



TNQ Academy Training Certification  
Testing and Conformity Assessment Inc.  
Certificate validity information  
certificate@tnqcert.com you can check at.  
709 N. King Street  
Suite 260 Wilmington  
DE 19801  
Country : USA  
E-mail: certificate@tnqcert.com  
turkey@tnqcert.com



The executing company issue a certificate which contains the following information with reference to this European Technical Assessment for each application place:

- Thermal insulation product made of loose, free cellulose fibres
- trade names
- executing company
- building project and building component
- date of installation
- processing procedure installation thickness

Certificate Publication Date: 21.11.2023  
Certificate Last Issue Date: 21.11.2023  
Certificate Expiry Date: 20.11.2024  
Certificate Period Expiry Date: 20.11.2026  
Certificate Number: ADA-TNQ-70156-2023-USA



**EUROPEAN TECHNICAL APPROVAL**  
**ETA-15/0355**



TNQ Academy Training Certification  
Testing and Conformity Assessment Inc.  
Certificate validity information  
certificate@tnqcert.com you can check at.  
709 N. King Street  
Suite 260 Wilmington  
DE 19801  
Country : USA  
E-mail: certificate@tnqcert.com  
turkey@tnqcert.com

